

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										0.0009			
EPA Site Specific Trigger Levels										NA			
ASBESTOS-ST1-1/22/11	031101901-0001	Southwest Area (sidewalk bridge level)	1/22/11	1	3.050	Asbestos	PCME	EMSL	1/24/11	< 0.00081	No	No	
ASBESTOS-ST2-1/22/11	031101901-0002	Southeast Area (sidewalk bridge level)	1/22/11	1	3.000	Asbestos	PCME	EMSL	1/24/11	< 0.00082	No	No	
ASBESTOS-ST5-1/22/11	031101901-0003	Firehouse #10 (roof level)	1/22/11	1	3.100	Asbestos	PCME	EMSL	1/24/11	< 0.00080	No	No	
ASBESTOS-ST23-1/22/11	031101901-0004	Northwest Area (sidewalk bridge level)	1/22/11	1	3.030	Asbestos	PCME	EMSL	1/24/11	< 0.00081	No	No	
ASBESTOS-ST1-1/23/11	031101900-0001	Southwest Area (sidewalk bridge level)	1/23/11	1	2.970	Asbestos	PCME	EMSL	1/24/11	< 0.00083	No	No	
ASBESTOS-ST2-1/23/11	031101900-0002	Southeast Area (sidewalk bridge level)	1/23/11	1	3.100	Asbestos	PCME	EMSL	1/24/11	< 0.00080	No	No	
ASBESTOS-ST5-1/23/11	031101900-0003	Firehouse #10 (roof level)	1/23/11	1	3.000	Asbestos	PCME	EMSL	1/24/11	< 0.00082	No	No	
ASBESTOS-ST23-1/23/11	031101900-0004	Northwest Area (sidewalk bridge level)	1/23/11	1	2.980	Asbestos	PCME	EMSL	1/24/11	< 0.00083	No	No	