

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										0.0009			
EPA Site Specific Trigger Levels										NA			
ASBESTOS-ST1-2/2/11	031102735-0001	Southwest Area (sidewalk bridge level)	2/2/11	1	3.070	Asbestos	PCME	EMSL	2/3/11	< 0.00080	No	No	
ASBESTOS-ST2-2/2/11	031102735-0002	Southeast Area (sidewalk bridge level)	2/2/11	1	3.120	Asbestos	PCME	EMSL	2/3/11	< 0.00079	No	No	
ASBESTOS-ST5-2/2/11	031102735-0003	Firehouse #10 (roof level)	2/2/11	1	3.070	Asbestos	PCME	EMSL	2/3/11	< 0.00080	No	No	
ASBESTOS-ST23-2/2/11	031102735-0004	Northwest Area (sidewalk bridge level)	2/2/11	1	3.120	Asbestos	PCME	EMSL	2/3/11	< 0.00079	No	No	